

FIXTURE UNIT WORKSHEET

Date:

Business Name:

Address:

Business Type:

Inspector:

SUMMARY & NEW ADDITIONAL FIXTURES

PLUMBING APPLIANCE / FIXTURE	PRIVATE			PUBLIC			ASSEMBLY		
	QTY	F.U.	SUB	QTY	F.U.	SUB	QTY	F.U.	SUB
Bathtub or Combo Bath/Shower		x 2 =	0		x 2 =	0			
Clothes Washer		x 3 =	0		x 3 =	0		x 3 =	0
Dental Units/ Cuspidor					x 1 =	0		x 1 =	0
Dishwasher - Domestic		x 2 =	0		x 2 =	0		x 2 =	0
Dishwasher - Commercial					x =	0		x =	0
Drinking Fountain (Per Head)		x 0.5 =	0		x 0.5 =	0		x 1 =	0
Floor Drain (2")		x 2 =	0		x 2 =	0		x 2 =	0
Shower - Single Head		x 2 =	0		x 2 =	0		x 2 =	0
Shower - Multiple Head, each additional		x 1 =	0		x 1 =	0		x 1 =	0
Sink - Bar		x 1 =	0		x 2 =	0		x 2 =	0
Sink - Commercial (Other than Lavatory)					x 3 =	0		x 3 =	0
Sink - Floor (Indirect waste. See footnote ^{1 & 2})					x =	0		x =	0
Sink - Floor (Condensate / Low Flow)					x 1 =	0		x 1 =	0
Sink - Laundry		x 2 =	0		x 2 =	0		x 2 =	0
Sink - Wash Fountain (2")					x 3 =	0		x 3 =	0
Sink - Hand wash / Lavatory		x 1 =	0		x 1 =	0		x 1 =	0
Sink - Service or Mop Sink					x 3 =	0		x 3 =	0
Sink- Service, Flushing rim					x 6 =	0		x 6 =	0
Sink - Shampoo					x 2 =	0		x 2 =	0
Urinal, 1.0 GPF		x 2 =	0		x 2 =	0		x 5 =	0
Water Closet, 1.6 GPF		x 3 =	0		x 4 =	0		x 6 =	0
Water supply inlets to fixtures for items not listed above shall be computed at their maximum demand but in no case less than:									
Inlet size of 3/8 inch or smaller		x 1 =	0		x 2 =	0			
Inlet size 1/2 inch		x 2 =	0		x 3 =	0			
Inlet size of 3/4 inch		x 3	0		x 6	0			
Inlet size of 1 inch		x 6	0		x 10	0			
Inlet size greater than 1 inch		x 10 =	0		x 18 =	0			
	Sub Total:		0.0	Sub Total:		0.0	Sub Total:		0.0
	Total New / Additional Fixtures:								

COMMENTS:

Ref: 2007 California Plumbing Code, Table 7-3

1. Indirect waste receptors shall be sized based on the total drainage capacity of the fixtures that drain therein to, in accordance with table 7-4

2. For Commercial sinks, dishwashers and similar moderate or heavy demands.