



City of Coachella  
1515 Sixth Street, Coachella, California 92236

Phone (760) 398-5744 [www.coachella.org](http://www.coachella.org)

## ADDENDUM NUMBER 2

**DATE:** November 19, 2014

**TO:** All Prospective Bidders and Plan Holders

### CONSTRUCTION OF SPEED HUMPS CITY PROJECT No. ST-53

**1. What is the length of Speed Humps:**

*Answer: The length of the speed humps goes from edge of gutter-to-edge of gutter, depending of the width of the street in the city varies from 35 feet to 40 feet.*

***The Contractor is hereby notified; Addendum No. 2 must be acknowledged as stipulated under Section "INSTRUCTIONS TO BIDDERS", ADDENDA OR BULLETINS, and submitted as part of the Bid. Failure to do so shall result in the City designating said bid as "Non-Responsive".***

**APPROVED:**

Jonathan D. Hoy  
Jonathan D. Hoy, PE, City Engineer

**BIDDER ACKNOWLEDGMENT:**

\_\_\_\_\_  
Signature acknowledging receipt of Addendum No. 1

\_\_\_\_\_  
Printed Name & Date

\_\_\_\_\_  
Company