





NOTES:

1. ALL METALLIC MATERIALS SHALL BE CAST IRON OR DUCTILE IRON.
2. FRAME AND LID SHALL HAVE CAST SEAT AND SIDE TO ASSURE CLOSE FIT.
3. FOR INSTALLATION, SEE STANDARD DRAWING **W-12**
4. FRAME AND LID SHALL EXCEED H-20 WHEEL LOADING.
5. APPROVED MODELS:
 - 10 INCH HEAVY MARK V TRI RIM W/FLANGE MODEL NO. GRE10RTF MANUFACTURED BY BINGHAM & TAYLOR
 - 10 INCH MARK V TRI LID CVWD-WATER YELLOW POWDER MODEL NO. CUL10LTCVWD-W MANUFACTURED BY BINGHAM & TAYLOR CONFIRM COLOR WITH CITY PRIOR TO ORDERING

APPROVED:

R.C.E. 72868
EXP. 6/30/24

CITY OF COACHELLA

**DETAIL OF DOMESTIC WATER VALVE
OPERATOR WELL CAP AND FRAME**

AUGUST 2023

DRAWING NUMBER: W-12.1